



TÜRK STANDARDLARI ENSTİTÜSÜ
TÜRK STANDARDLARINA UYGUNLUK BELGESİ
TURKISH STANDARDS INSTITUTION
CERTIFICATE OF CONFORMITY TO TURKISH STANDARDS


Markanın Tanımı Description of the Mark
TSE veya/or  veya/or **T S E**

BELGE NUMARASI <i>REFERENCE NUMBER OF LICENCE</i>	14.0.30.4.34.00/TSE-64200
BELGENİN İLK VERİLİŞ TARİHİ <i>DATE OF FIRST ISSUE OF LICENCE</i>	24.01.2013
BELGENİN SON GEÇERLİLİK TARİHİ <i>LICENCE VALID UNTIL</i>	24.01.2017
BELGE SAHİBİ KURULUŞUN ADI <i>NAME OF THE LICENCE HOLDER</i>	DUYAR VANA MAKİNA SANAYİ VE TİCARET ANONİM ŞİRKETİ
BELGE SAHİBİ KURULUŞUN ADRESİ <i>ADDRESS OF THE LICENCE HOLDER</i>	UĞUR MUMCU MAH. 2347 SOK. NO:7 34265 SULTANGAZI İSTANBUL/TÜRKİYE
ÜRETİM YERİ ADI <i>NAME OF THE MANUFACTURING PLACE</i>	DUYAR VANA MAKİNA SANAYİ VE TİCARET A.Ş.
ÜRETİM YERİ ADRESİ <i>ADDRESS OF THE MANUFACTURING PLACE</i>	UĞUR MUMCU MAH. 2347 SOK. NO:7 SULTANGAZI İSTANBUL / TÜRKİYE
İPTAL EDİLEN BELGE NUMARASI (Varsa) <i>INDICATION OF SUPERSEDED LICENCE (if any)</i>	
TESCİLLİ TİCARİ MARKASI <i>REGISTERED TRADE MARK</i>	DUYAR+ŞEKİL
İLGİLİ TÜRK STANDARDI <i>RELATED TURKISH STANDARD</i>	TS EN 12259-1+A1 / Sabit Yangın Söndürme Sistemleri- Sprinkler ve Su Püskürtme Elemanları- Bölüm 1: Sprinkler / 15.04.2002
BELGE KAPSAMI <i>SCOPE OF LICENCE</i>	

*SABIT YANGIN SÖNDÜRME SİSTEMLERİ İÇİN SPRİNKLER ;

*DN 15 OTOMATİK, TAVAN(veya fişkırtma) TİPİ KAPLANMAMIŞ, DÜZ PÜSKÜRTMELİ , CAM AMPÜLLÜ
-ASILI TİP SPRİNKLER
-YAN DUVAR TİP SPRİNKLER
-YUKARI DOĞRU YÖNLENDİRİLMİŞ SPRİNKLER

12/01.2016



AHMET NURSİ KARTAL
TSE İSTANBUL BELGELENDİRME
MÜDÜRÜ

CERTIFICATE OF COMPLIANCE

Certificate Number 20160707-EX16350
Report Reference EX16350-20150618
Issue Date 2016-JULY-07

Issued to: DUYAR VANA MAKINA SAN VE TIC A S
Ugur Mumcu Mah
2347. Sok. No.7
Sultangazi
34265 Istanbul TURKEY

This is to certify that representative samples of SPRINKLERS, AUTOMATIC AND OPEN
See Addendum Page

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety: UL199, Automatic Sprinklers for Fire-Protection.
Additional Information: See the UL Online Certifications Directory at www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number 20160707-EX16350
Report Reference EX16350-20150618
Issue Date 2016-JULY-07

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Automatic sprinklers incorporating a 5mm glass bulb heat responsive element in the following models, types and temperature ratings.

Listing	SIN	Description	Temperature Ratings, °F
USL	DY3323	Upright 5.6 K, standard response glass bulb style sprinkler plain brass or white painted	135, 155, 175
USL	DY3327	Pendent 5.6 K, standard response glass bulb style sprinkler plain brass or white painted	135, 155, 175



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

