

C € 0085



CERT

EU type examination certificate

EU-Baumusterprüfbescheinigung

CE-0085CT0184

Product Identification No.
Produkt-Identnummer

Field of Application <i>Anwendungsbereich</i>	EU Gas Appliances Regulation (EU/2016/426) <i>EU-Gasgeräteverordnung (EU/2016/426)</i>
Owner of Certificate <i>Zertifikatinhaber</i>	Ferrolì S.p.A. Via Ritonda 78A, I-37047 San Bonifacio (VR)
Distributor <i>Vertreiber</i>	Ferrolì S.p.A. Via Ritonda 78A, I-37047 San Bonifacio (VR)
Product Category <i>Produktart</i>	Boilers with flue systems: Condensing combi water heater (3204)
Product Description <i>Produktbezeichnung</i>	Condensing combi water heater optional also as condensing water heater
Model <i>Modell</i>	BLUEHELIX TECH RRT...
Countries of Destination <i>Bestimmungsländer</i>	AL, AT, BE, BG, CH, CY, CZ, DE, DK, EE, ES, FI, FR, GB, GR, HR, HU, IE, IS, IT, LT, LU, LV, MK, MT, NL, NO, PL, PT, RO, SE, SI, SK, TR
Test Reports <i>Prüfberichte</i>	type testing: K 2107 2017 B2 from 14.05.2018 (TRG) type testing: K 2107 2017 T1 from 14.05.2018 (TRG)
Test Basis <i>Prüfgrundlagen</i>	EU/2016/426 A III B (09.03.2016) DIN EN 13203-1 (01.12.2015) DIN EN 15502-2-1 (01.09.2017)
Date of Expiry / File No. <i>Ablaufdatum / AZ</i>	06.07.2028 / 17-0847-GEE

06.07.2018 Rie A-1/2

Date, Issued by, Sheet, Head of Certification Body
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle

DVGW CERT GmbH is an accredited body by DAkkS according to DIN EN ISO/IEC 17065:2013 and notified by the government of the Federal Republic of Germany for certification of gas appliances under EU Regulation

DVGW CERT GmbH ist von der DAkkS nach DIN EN ISO/IEC 17065:2013 akkreditierte und von der Deutschen Bundesregierung benannte Stelle für die Zertifizierung von Gasgeräten gemäß EU-Verordnung EU/2016/426.



Deutsche
Akkreditierungsstelle
D-ZE-16028-01-01

DVGW CERT GmbH
Zertifizierungsstelle

Josef-Wirmer-Str. 1-3
53123 Bonn

Tel. +49 228 91 88 - 888
Fax +49 228 91 88 - 993

www.dvgw-cert.com
info@dvgw-cert.com

Type Typ	Technical Data Technische Daten	Remarks Bemerkungen
BLUEHELIX TECH RRT 18 H	nominal heat output: 4,9...18,0 kW heat input (Hi): 5,0...18,4 kW	
BLUEHELIX TECH RRT 24 C	nominal heat output: 4,9...20,0 kW heat input (Hi): 5,0...20,4 (drinking water: ...25,0) kW	
BLUEHELIX TECH RRT 28 C; BLUEHELIX TECH RRT 24 H; BLUEHELIX TECH RRT 24 S	nominal heat output: 4,9...24,0 kW heat input (Hi): 5,0...24,5 (drinking water: ...28,5) kW	
BLUEHELIX TECH RRT 34 C; BLUEHELIX TECH RRT 30 H; BLUEHELIX TECH RRT 30 S	nominal heat output: 6,3...30,0 kW heat input (Hi): 6,4...30,6 (drinking water: ...34,7) kW	

Type Variation Ausführungsvariante	Explanations Erläuterungen
...C	condensing combi water heater
...H	condensing water heater
...S	condensing water heater only for GB

Hints of Utilization /Remarks

Verwendungshinweise / Bemerkungen

Flue types B23, B33, C13(x), C23, C33(x), C43(x), C53(x), C63(x), C83(x), C93(x): according to installation manual with flue system of Groppalli (2592-CPR-001)

Approved appliance categories, supply pressures and countries of destination:

I2N (20/25 mbar): BE, FR

I2N (20 mbar): CZ, ES, GR, PT, SI

I2E (20mbar): LU, RO

I2H (20 mbar): FR, NL

I3B (37 mbar): ES, IE

I3B/P (30 mbar): BE

I3B/P (37 mbar): GR, PT

I12E3B/P (20, 30 mbar): PL

I12E3B/P (20, 50 mbar): AL, DE, MK, PL

I12H3B/P (20, 30 mbar): BG, CY, DK, EE, FI, HR, HU, IS, IT, LT, MT, NO, RO, SE, SI, SK, TR

I12H3B/P (20, 37 mbar): GR, HR, LV

I12H3B/P (20, 50 mbar): AT, CH, CY, CZ, LU

I12H3P (20, 37 mbar): ES, GB, IE, PT

I12H3+ (20, 30/37mbar): CH, CY, CZ, ES, GB, GR, IE, IT, PT, SI, SK, TR

I12ELL3B/P (20, 50 mbar): DE

I12E+3+ (20/25, 30/37 mbar): BE, FR

I12E+3P (20/25, 37 mbar): BE

I12E+3B/P (20/25, 37 mbar): FR

I12HS3B/P (25, 30 and 50 mbar): HU

I12HM3B/P (20, 30 mbar): IT

I12L3B/P (25, 30 mbar) and I12EK3B/P (20/25, 30 mbar): NL

I12ELw3B/P (20, 13, 30 mbar): PL

In the NON-EU countries the CE-marking will be accepted as conformity approval if the Gas Appliance Regulation EU/2016/426 is transferred into national law by this countries.

DVGW