

# PAL SYSTEM INTERNATIONAL FZCO

## Pre-Insulated Ducting Technology

P.O. Box: 113826 DUBAI, UAE  
Tel +971 4 8105105 Fax +971 4 8105106  
E-mail: [info@palduct.com](mailto:info@palduct.com)  
Website: [www.pal-me.net](http://www.pal-me.net)



Al Qusais 2, Dubai Office  
Tel +971 4 2582640 Fax +971 4 2582641

## PAL ECO SYSTEM DUCT SYSTEM

### LIST OF TEST REPORT & CERTIFICATE

DESCRIPTION	TEST METHOD & STATEMENT	LABORATORY	CLASSIFICATION & RESULTS
Bacterial and Fungal Growth Resistance	ASTM G21	Biosan Laboratories	Resistance to the following organisms: <ul style="list-style-type: none"><li>• <i>Aspergillus niger</i></li><li>• <i>Aureobasidium pullulans</i></li><li>• <i>Chaetomium globosum</i></li><li>• <i>Penicillium funiculosum</i></li><li>• <i>Trichoderma virens</i></li></ul>
Bacterial and Fungal Growth Resistance	ASTM G22	Exova – Al Futtaim	No growth for the following organisms: <ul style="list-style-type: none"><li>• <i>Pseudomonas aeruginosa</i></li><li>• <i>Staphylococcus aureus</i></li></ul>
Bacterial Growth Resistance	ASTM E2180	Biosan Laboratories	Resistance to <i>Staphylococcus aureus</i>
Fire Propagation Index	BS 476 Part 6	Warringtonfire - UK	Class "0"
Surfaces Spread of Flame	BS 476 Part 7	Warringtonfire - UK	Class "1"
Certification of Product Listing No. 016	BS 476 Part 6, 7	Warringtonfire – UK, Mideast Global Safety	Class "0"
Certificate of Factory Production Control and Product Labels	FPC Requirement Product Label  Certificate of Approval ME0016	Warringtonfire – UK, Mideast Global Safety	
Flame Spread Index	ASTM E-84 NFPA 255 UL 723 NFPA 101 Life Safety Code	Commercial Testing Company - USA	Class "A"

# PAL SYSTEM INTERNATIONAL FZCO

## Pre-Insulated Ducting Technology

P.O. Box: 113826 DUBAI, UAE  
Tel +971 4 8105105 Fax +971 4 8105106  
E-mail: [info@palduct.com](mailto:info@palduct.com)  
Website: [www.pal-me.net](http://www.pal-me.net)



Al Qusais 2, Dubai Office  
Tel +971 4 2582640 Fax +971 4 2582641

DESCRIPTION	TEST METHOD & STATEMENT	LABORATORY	CLASSIFICATION & RESULTS
Smoke Developed Index	ASTM E-84 NFPA 255 UL 723 NFPA 101 Life Safety Code	Commercial Testing Company - USA	Class "A"
Toxicity Index	NES – 713 IMO Resolution MSC 61 (67)	Warringtonfire UK Warringtonfire UK	5.7 Average S.O.D. <200
Thermal Conductivity	ASTM C518	Dubai Municipality Laboratory	0.020 w/m.k. 0.169 Btu w/m.k. ft <sup>2</sup>
Compressive Strength	ASTM D1621	Dubai Municipality Laboratory	220.9 kpa
Flexural Strength	ASTM C203	Dubai Municipality Laboratory	1170 kpa
Panel Density	ASTM D1622	Dubai Municipality Laboratory	71.5 kg/m <sup>3</sup>
Water Absorption Level	ASTM C209	Dubai Municipality Laboratory	0.14% (24 hours immersion)
Sound Attenuation Test	BS 2750	Sound Research Laboratory Limited	Average SRI (100-3150 Hz) 14.1

## PAL PRE-INSULATED DUCT SYSTEM

### LIST OF TEST REPORT & CERTIFICATE

DESCRIPTION	TEST METHOD & STATEMENT	LABORATORY	CLASSIFICATION & RESULTS
1. Fire Propagation Index	BS 476 Part 6	Warringtonfire - UK	Class "0"
2. Surfaces Spread of Flame	BS 476 Part 7	Warringtonfire - UK	Class "1"
3. Certification of Product Listing No. 016	BS 476 Part 6, 7	Warringtonfire – UK, Mideast Global Safety	Class "0"
4. Certificate of Factory Production Control and Product Labels	FPC Requirement Product Label Certificate of Approval ME0016	Warringtonfire – UK, Mideast Global Safety	
5. Epiradiateur Test	NFP 92-501	Warringtonfire – UK (Ministere de l'Industrie et de la Decentralisation)	M1
6. Flame Spread Index	ASTM E-84 NFPA 255 UL 723 NFPA 101 Life Safety Code	Commercial Testing Company - USA	Class "A"
7. Smoke Developed Index	ASTM E-84 NFPA 255 UL 723 NFPA 101 Life Safety Code	Commercial Testing Company - USA	Class "A"
8. Toxicity Index	NES – 713 IMO Resolution MSC 61 (67)	Warringtonfire UK Warringtonfire UK	5.7 Average S.O.D. <200



# PAL MIDDLE EAST PIR LLC

Pre-Insulated Ducting Technology

P.O. Box: 113826, DUBAI, UAE

Tel.: +971 4 2582640 Fax: +971 4 2582641

E-mail: palme@emirates.net.ae

Website: www.pal-me.net



DESCRIPTION	TEST METHOD & STATEMENT	LABORATORY	CLASSIFICATION & RESULTS
9. Thermal Conductivity	ASTM C518	Dubai Municipality Laboratory	0.020 w/m.k. 0.169 Btu w/m.k. ft <sup>2</sup>
10. Compressive Strength	ASTM D1621	Dubai Municipality Laboratory	220.9 kpa
11. Flexural Strength	ASTM C203	Dubai Municipality Laboratory	1170 kpa
12. Panel Density	ASTM D1622	Dubai Municipality Laboratory	71.5 kg/m <sup>3</sup>
13. Water Absorption Level	ASTM C209	Dubai Municipality Laboratory	0.14% 24 hours immersion
14. Sound Attenuation Test	BS 2750	Sound Research Laboratory Limited	Average SRI (100-3150 Hz) 14.1
15. Fungal Resistance Test	ASTM G21	Biosan Laboratories - USA	No Fungal Growth



ISO 9001  
BUREAU VERITAS  
Certification



warringtonfire - mideast  
Listing No. 016  
PAL Panel Class O  
global safety



CB-013



## CLIENT INFORMATION

Company Name PAL SYSTEM

## SAMPLES:

Samples of rigid Pal Duct were submitted by the manufacturer for examination and test.

## GENERAL:

Test results relate only to the below items tested.

The following tests were conducted on representative sizes and samples of Pal Duct in accordance with UL 181, Factory Made Air Ducts and Air Connectors, Eleventh Edition, dated July, 25, 2013.

Tests	Section	Size Tested	Thickness Tested	Interior	Status
Surface Burning Characteristics	7	as required	20 and 30 mm	Reinforced and non-reinforced	Passed
Flame Penetration	10	as required	20 and 30 mm	Reinforced and non-reinforced	Passed
Burning	11	500 by 500 mm; 300 by 300 mm	20 mm	Non-reinforced	Passed
Mold Growth and Humidity - caulk and duct section	13	as required	20 mm	Non-reinforced	Passed
Temperature (low)	14	as required	20 mm	Non-reinforced	Passed
Temperature (high)	14	as required	20 mm	Non-reinforced & Reinforced	Passed
Puncture	15	as required	20 and 30 mm	Non-reinforced & Reinforced	Passed
Puncture after High Temp	15	as required	20 mm	Non-reinforced & Reinforced	Passed
Static Load	16	500 by 500 mm; 300 by 300 mm	30 mm	Non-reinforced & Reinforced	Passed
Impact	17	500 by 500 mm	20 mm	Non - reinforced	Passed



Erosion	18	as required	20 mm	Non-reinforced	Passed
Pressure	19	500 by 500 mm; 300 by 300 mm	30 mm	Non-reinforced	
Collapse	20	500 by 500 mm; 300 by 300 mm	20 mm	Non-reinforced	

The following identification tests were also conducted:

Cone Calorimeter - Foam Core  
 Qualitative Infrared Analysis - Foam Core  
 Thermogravimetric Analysis - Foam Core

The materials used in this investigation were produced under the observation of a representative of UL LLC, in a ready-to-use form. The composition of the finished materials is of a proprietary nature. Data on the composition is on file at the Laboratories for use in the Follow-Up Service Program.

#### Test Record Summary:

The results of this investigation, including construction review and testing, indicate that the product evaluated complies with the applicable requirements in the Eleventh Edition of UL 181, Factory Made Air Ducts and Air Connectors, dated July 25, 2013 and therefore, such product is judged eligible to bear UL's Mark as described on the Conclusion Page of this Report.



## Erosion Test Method

Air is to be passed through the sample at test velocity with the collecting screen removed for a period of at least 1 hour and not more than 24 hours. **The collection screen then is to be placed in position.**

The test then is to proceed at test velocity and continued for a period of 4 hours. The collecting screen is to be examined for macroscopic particles at the end of each hour during the test period by taping the screen with the adhesive side of transparent tape, or tapes, in order to remove and record any eroded particles.

Manufacturer's Rated Velocity 20 m/sec = **3937** ft/min

Two and one-half times Rated Velocity 9843 ft/min

Test Velocity 9843 ft/min (not < 2500 FPM)

## RESULTS

Material for air ducts and air connectors did / did not break away, crack, peel, flake off, or show evidence of delamination or continued erosion when air is passed through typical sections at a velocity of two and one-half times the manufacturer's rated velocity, and not less than 2500 feet per minute (762 m/min). For the purpose of this requirement, continued erosion is identified to be either a constant or increasing rate of erosion.

## Examinations at One-Hour Intervals

2nd Hour - 0 Pieces of fiber collected  
3rd Hour - 0 Pieces of fiber collected  
4th Hour - 0 Pieces of fiber collected  
5th Hour - 0 Pieces of fiber collected

## Observations

Breakage	<u>X</u>	No	<u>    </u>	Yes
Cracking	<u>X</u>	No	<u>    </u>	Yes
Peeling	<u>X</u>	No	<u>    </u>	Yes
Flaking	<u>X</u>	No	<u>    </u>	Yes
Evidence of Delamination	<u>X</u>	No	<u>    </u>	Yes

**X**[Pass] [Fail]

Project No. 13CA55647

File MH49717

Tested by: Craig Ebbeskotte

Printed Name

Craig Ebbeskotte

Signature

Date 4/22/2014

TEST RECORD NO. 2

SAMPLES



At the request of the submitter, a pigment (0.9 Wt.% of overall formulation) was added to the foam core to change the color from pink to grey in Vol. 1, Sec.1 of File MH49717.

#### RESULT

Addition of a pigment of such a small Wt. % would not affect the test performance of the air duct in accordance with UL 181 Standard. Therefore, no testing was deemed necessary.

#### TEST RECORD No. 2 SUMMARY

The results of this investigation, including construction review and testing, indicate that the product evaluated complies with the applicable requirements in the Eleventh Edition of UL 181, Factory Made Air Ducts and Air Connectors dated July 25, 2013 and therefore, such product is judged eligible to bear UL's Mark as described on the Conclusion Page of this Report.

Very truly yours,

A handwritten signature in cursive script that reads "Jamila Shawon".

Jamila Shawon (Ext. 42607)  
Senior Project Engineer  
Fire Protection Division

Reviewed by,

A handwritten signature in cursive script that reads "Dwayne E. Sloan".

Dwayne Sloan  
Principal Engineer Manager

Any information and documentation provided to you involving UL Mark services are provided on behalf of UL LLC. (UL) or any authorized licensee of UL.





## CONCLUSION:

Samples of the product covered by this Report have been found to comply with the requirements covering the category and the product is found to comply with UL's applicable requirements. The description and test result in this Report are only applicable to the samples investigated by UL and does not signify UL certification or that the product described are covered under UL's Follow-Up Service Program. When covered under UL's Follow-Up Service Program, the manufacturer is authorized to use the UL Listing Mark on such products which comply with UL's Follow-Up Service Procedure and any other applicable requirements of UL LLC. The Listing Mark of UL LLC on the product, or the UL symbol on the product and the Listing Mark on the smallest unit container in which the product is packaged, is the only method to identify products investigated by UL to published requirements and manufactured under UL's Listing and Follow-Up Service.

This Report is intended solely for the use of UL LLC (UL) and the Applicant for establishment of UL certification coverage of the described product under UL's Follow-Up Service. UL retains all rights, title and interest (including exclusive ownership) in this Report and all copyright therein. The Applicant or its designated agent shall not disclose or otherwise distribute this Report or its contents to any third party, except as required for purposes of compliance with laws, regulations, or other existing agreements or schemes in which UL is currently a participant. Any other use of this Report including, without limitation, evaluation or certification by a party other than UL is prohibited and renders this Report null and void. UL shall not incur any obligation or liability for any loss, expense, or punitive damages, arising out of, or in connection with, the use or reliance upon the contents of this Report to anyone other than the Applicant as provided in the agreement between UL and Applicant. Any use or reference to UL's name or certification mark(s) by anyone other than the Applicant in accordance with the agreement is prohibited without the express written approval of UL. Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. UL shall not otherwise be responsible to anyone for the use of or reliance upon the contents of this Report.

Report by:

A handwritten signature in cursive script that reads "Jamila Shawon".

Jamila Shawon  
Senior Project Engineer  
Building Materials & Life Safety  
Technology

Reviewed by:

A handwritten signature in cursive script that reads "Dwayne E. Sloan".

Dwayne Sloan  
Principal Engineer  
Building Materials & Life Safety  
Technology